

*This is to certify that*

*The Cleanroom at*

**Unit 15-16F, UG, Wah Lok Industrial Centre Phase 2  
31 - 35 Shan Mei Street, Fo Tan, N.T., Hong Kong SAR**

*of Ownership*

**Real Care Limited**

***Complies with the Acceptance Criteria of***

***BS EN ISO 14644-1: 2015: Class 8***

***(Ambient Particle Concentration, HEPA filter leakage, Air Change Per Hour & Pressure Differential)***

***EU GMP & PIC/S PE 010-3: Grade D***

***(Viable Particle Cleanliness)***

***As detailed in***

**Test Report No.:** RP2000156 &(1)

**Date of Certification:** 03/09/2020

**Date of expiry:** 03/09/2021

**Date of issue:** 14/09/2020

**Certified by:**

  
**Mr Donney Man Wai Leung**  
Biosafety Consultant, MSc, MBA, BSc  
NEBB Certified Cleanroom Professional

**The Lab (Asia) Ltd.**

22 San Hi Tsuen Street,  
Ping Shan, N.T., Hong Kong.

Tel: +(852) 2470 2588  
Fax: +(852) 2470 2589  
Email: [info@thelab.asia](mailto:info@thelab.asia)  
Website: [www.thelab.asia](http://www.thelab.asia)

